



HANGAR DUCT DIAGRAM (STEAM HEATER SYSTEM)

REV.	DESCRIPTION	DWN.	CHECKED	DATE
△				



STEAM VALVE PANEL



Q'TY : 1SET
WEIGHT : 75Kg
(TO BE ATTACHED TO UNIT)

WELDING TYPE	
13	INSULATION
12	BALL VALVE+TUBE 1 JS 10K - 10A
11	DIAL THERMOMETER 1 0 ~ 200°C
10	PRESS. GAUGE 1 000 0 ~ 10kg
9	STEAM REG. VALVE 1 KTE-TYPE
8	STRAINER 1 JS 10K - FF 25A
7	STEAM TRAP 1 JS 10K - FF 20A
6	DRAIN VALVE 2 JS 10K COPPER TUBE 10A
5	GLOVE VALVE 2 JS 10K - FF 25A
4	GLOVE VALVE 1 JS 10K - FF 20A
3	GLOVE VALVE 1 JS 10K - FF 25A
2	FLANGE 4 JS 10K - FF 20A
1	FLANGE 4 JS 10K - FF 25A

12	SUPPORTING BAR	1Lot	L40x40x5t
11	COUNTER FLANGE	2	MK-S
10	CABLE GLAND	2	KS-TYPE
9	HANDLE	1Lot	MK-S
8	SUPPORTING BAR	1Lot	PL40x6t
7	SUPPORTING BAR	1Lot	L40x40x5t
6	DAMPER HANDLE	1Lot	MK-S
5	PUNCHING METAL	1Lot	SUS304
4	FAN MOTOR	1Lot	AC440V,3Ph,60Hz,4P
3	FAN	1Lot	PTAXE-004S
2	DUCT	1Lot	AL 2.0t
1	STEAM COIL	1	5/8"x4Rx400Hx560L
No.	NAME	Q'ty	REMARK'S

PROJECT SHIP No.	HANJIN HEAVY IND. CO.,LTD. S.046, 047	TITLE	STEAM DUCT HEATER	
DATE	-	닥터 제작 설치도		
APPROVED BY		SCALE	DWG. No.	-
CHECKED BY		REV. No.	PAGE No.	-
DRAWN BY	Jong. Sam CHOI	KOREA INTERCOOL CO., LTD. HVAC & REP. SYSTEM SHIP ENGINEERING. KIG TEL : 82-51-284-2810 Fax : 82-51-284-2803		

