

**REF PLANT NAME**

**CORPSE ROOM**

1. DESIGN CONDITION

1) Temperature Condition

Open Air		35	℃
Sea Water		36	℃
Deck	sunshine	60	℃
	shade	37	℃
Wall	sunshine	50	℃
	shade	37	℃
Engine Room		45	℃
Passage		35	℃
Conditioned Room		33	℃
Unconditioned Room		35	℃
Galley		40	℃

2) Refrigeration provision chamber

ROOM	Volume (m <sup>3</sup> )	Temperature (℃)	Cooler type	Defrost method	Remarks
Corpse Room No1	14.3	0.6	UC	EH	UC : Unit Cooler GC : Grid Coil AF : Agitator Fan HG : Hot Gas EH : Electric Heater
Corpse Room No2			UC	EH	
			UC	EH	
			UC	EH	
<b>TOTAL</b>	<b>14.3</b>				

3) Heat Transmission Coefficient

Part	Specification	K (kcal/m <sup>2</sup> h℃)	Remarks
Ceiling	100t PU	0.319	PW : Ply Wood PU : Polyurethane Foam CM : Cement Mortar QT : Quarry Tile VR : Vinyl Roofing NT : Non slip Tile
Floor	150t PU	0.447	
Side Wall	100t PU	0.319	
Partition Wall			

## 2. CALCULATION OF THE EACH ROOM

### 2.1 CORPSE ROOM No.1

Room Volume	14.3	(m <sup>3</sup> )
Room Temperature	0.6	(°C)

#### 1) Transmission Heat Gain, Q<sub>T</sub> (kcal/h)

Part	Area (m <sup>2</sup> )		K (kcal/m <sup>2</sup> h°C)	Δt (°C)	Q (kcal/h)
Ceiling	1.6	× 4.6	0.319	58	136.2
Floor	1.6	× 4.6	0.447	35	115.1
Side Wall In Side	1.6	× 2.6	0.319	33	43.8
	1.6	× 2.6		33	43.8
Partition Wall Out side	4.6	× 2.6	0.319	33	125.9
	4.6	× 2.6		48	183.1
<b>SUB TOTAL</b>					<b>647.9</b>

#### 2) Infiltration Heat(Door), Q<sub>a</sub> (kcal/h)

$$\begin{aligned}
 Q_a &= 14.3 \text{ (m}^3\text{)} \times 6 \text{ (T/day)} \times 24.80 \text{ (kcal/m}^3\text{)} \\
 &= 88.7 \text{ (kcal/h)}
 \end{aligned}$$

#### 3) Internal heat for motor, Q<sub>m</sub> (kcal/h)

$$\begin{aligned}
 Q_m &= P \text{ kW} \times 1/\eta_m \times \xi/24 \times 860 \text{ kcal/h/kW} \\
 &= 0.20 \times (1 / 0.85) \times (14 / 24) \times 860 \times 2 \text{ set(s)} \\
 &= 236.1 \text{ (kcal/h)}
 \end{aligned}$$

#### 4) Other, Q<sub>o</sub> (kcal/h)

$$\begin{aligned}
 Q_o &= ( Q_T + Q_a + Q_m ) \times 0 \\
 &= 972.7 \times 0.2 \\
 &= 194.5 \text{ (kcal/h)}
 \end{aligned}$$

#### 5) TOTAL HEAT LOAD : 1167.2 kcal/h

**2.2 CORPSE ROOM No.2**

Room Volume	0.0	(m <sup>3</sup> )
Room Temperature	0	(°C)

**1) Transmission Heat Gain, Q<sub>T</sub> (kcal/h)**

Part	Area (m <sup>2</sup> )		K (kcal/m <sup>2</sup> h°C)	Δt (°C)	Q (kcal/h)
Ceiling	0.0	× 0.0	0.319	0	0.0
Floor	0.0	× 0.0	0.447	0	0.0
Side Wall	0.0	× 0.0	0.319	0	0.0
		×			0.0
		×			0.0
Partition Wall		×	0.000	0	0.0
		×		0	0.0
		×			0.0
<b>SUB TOTAL</b>					<b>0.0</b>

**2) Infiltration Heat(Door), Q<sub>a</sub> (kcal/h)**

$$\begin{aligned}
 Q_a &= 0.0 \text{ (m}^3\text{)} \times 6 \text{ (T/day)} \times 8.80 \text{ (kcal/m}^3\text{)} \\
 &= 0.0 \text{ (kcal/h)}
 \end{aligned}$$

**3) Internal heat for motor, Q<sub>m</sub> (kcal/h)**

$$\begin{aligned}
 Q_m &= P \text{ kW} \times 1/\eta_m \times \xi/24 \times 860 \text{ kcal/h/kW} \\
 &= 0.20 \times (1 / 0.85) \times (14 / 24) \times 860 \times 0 \text{ set(s)} \\
 &= 0.0 \text{ (kcal/h)}
 \end{aligned}$$

**4) Other, Q<sub>o</sub> (kcal/h)**

$$\begin{aligned}
 Q_o &= ( Q_T + Q_a + Q_m ) \times 0 \\
 &= 0.0 \times 0.2 \\
 &= 0.0 \text{ (kcal/h)}
 \end{aligned}$$

**5) TOTAL HEAT LOAD : 0.0 kcal/h**

### 2.3 FISH ROOM

Room Volume	0.0	(m <sup>3</sup> )
Room Temperature	0	(°C)

#### 1) Transmission Heat Gain, Q<sub>T</sub> (kcal/h)

Part	Area (m <sup>2</sup> )		K (kcal/m <sup>2</sup> h°C)	Δt (°C)	Q (kcal/h)
Ceiling	0.0	× 0.0			0.0
Floor	0.0	× 0.0			0.0
Side Wall		×	0.000		0.0
		×			0.0
Partition Wall		×	0.000		0.0
		×			0.0
<b>SUB TOTAL</b>					<b>0.0</b>

#### 2) Infiltration Heat(Door), Q<sub>a</sub> (kcal/h)

$$\begin{aligned}
 Q_a &= 0.0 \text{ (m}^3\text{)} \times 6 \text{ (T/day)} \times 0.00 \text{ (kcal/m}^3\text{)} \\
 &= 0.0 \text{ (kcal/h)}
 \end{aligned}$$

#### 3) Internal heat for motor, Q<sub>m</sub> (kcal/h)

$$\begin{aligned}
 Q_m &= P \text{ kW} \times 1/\eta_m \times \xi/24 \times 860 \text{ kcal/h/kW} \\
 &= 0.40 \times (1 / 0.85) \times (14 / 24) \times 860 \times 0 \text{ set(s)} \\
 &= 0.0 \text{ (kcal/h)}
 \end{aligned}$$

#### 4) Other, Q<sub>o</sub> (kcal/h)

$$\begin{aligned}
 Q_o &= ( Q_T + Q_a + Q_m ) \times 0 \\
 &= 0.0 \times 0.2 \\
 &= 0.0 \text{ (kcal/h)}
 \end{aligned}$$

**5) TOTAL HEAT LOAD : 0.0 kcal/h**

### 3. TOTAL HEAT GAIN

ROOM	24hr running	14hr running
CORPSE ROOM No.1	1167.2	2000.9
CORPSE ROOM No.2	0.0	0.0
<b>TOTAL</b>	<b>1167.2</b>	<b>2000.9</b>

### 4. NECESSARY COOLING CAPACITY (ALLOWANCE 20 %)

COOLING CAPACITY : TOTAL HEAT GAIN × 1.2  
 2000.9 × 1.2 = 2,401 kcal/h

### 5. SPECIFICATION OF THE REF. MACHINE

Model No.	:	KIC-RU22	
Capacity	:	2,401	(kcal/h)
Condensing Temp.	:	45	(°C)
Evaporating Temp.	:	-5	(°C)
Revolution	:	1,400	RPM
Refrigerant	:		
Condenser Water Flow	:		(m <sup>3</sup> /h)
Motor Output	:	2.2	(kW)

### 6. COOLER

ROOM	Heat Gain (kcal/h)	Δt (°C)	K (kcal/m <sup>2</sup> h)	Cooling Area (m <sup>2</sup> )	Fin Pitch (mm)	Type
Corpse room1	2000.9	8	18	13.8	6.5	
Corpse room2	0.0	0	0	0		
실제사용				14.3		J040 PEC

※ REMARK

- : ΔT - Temperature difference between the Room Temp. and Evaporating Temp.
- : K - Heat transmission coefficient of the cooler