

HEAT LOAD CALCULATION

PACKAGED FOR TRANSFORMER

STX-0702-SB

1. DESIGN CONDITION

A. Temperature

	SUMMER	WINTER
OUTSIDE AIR	(T _{OS}) 35 °C DB 70 % RH	(T _{OW}) -25 °C DB % RH
ROOM AIR	(T _{RS}) 22 °C DB 50 % RH	(T _{RW}) 20 °C DB 50 % RH
FRESH AIR	32 °C	°C

B. Fresh air ratio

- SUMMER 10 %
- WINTER 10 %
- MIN. FRESH AIR 25.5 m³/h.pers

C. Air change per hour

- (a) Transformer room : 6 T/h

D. Steam pressure kg/cm²G

2. RESULT OF THE CALCULATION

A. Summer condition

1) Total Heat Gain

Q_R = 10,804 kcal/h

a) Sensible Heat Gain (Q_S)

10,741 kcal/h

- Transmission Heat Gain 4,315 kcal/h
- Solar Heat Gain - kcal/h
- Equipment Heat Gain 63,365 kcal/h
- Light Heat Gain 205 kcal/h
- Heat Emission (person) 150 kcal/h

b) Latent Heat Gain (Q_L)

Q_L = 63 kcal/h

2) SHF(Sensible Heat Factor)

0.99

3) Air Flow Rate

V_F = 25,845 m³/h

a) Normal room

V_N = 23,494 m³/h

b) Final air volume (selection)

V_F = 25,845 m³/h

4) Cooling capacity

Q_C = 146,351 kcal/h

a) Return Air Temperature T_B = 22.0 °C % RH

$T_B = T_R + 0.0 \text{ °C}$

b) Air-cooler Inlet(Mixed) Air temp. T_{C1} = 23.3 °C 53 % RH

c) Air-cooler Outlet Air temp. T_{C2} = 11.0 °C 95 % RH

$T_{C2} = T_R - 11.0 \text{ °C}$

d) Cooling Capacity

$Q_C = V_F \times \Delta i_c \times (1/v) = 146,351 \text{ kcal/h}$

Δi_c : The difference of the enthalpy 4.70 kcal/kg

v : The specific volume 0.83 m³/kg

B. Winter condition

1) Total Heat Loss

Q_R = -1,953 kcal/h

2) Air Flow Rate

V_F = 25,845 m³/h

3) Heating Capacity

Q_H = 11,765 kcal/h

a) Heater outlet air temp.

$T_F = T_R + Q_H / (C_P \times 1/v \times V_F) \text{ °C}$ T_F = 19.7 °C > 32°C

T_R : Room inside air temp. 20 °C

C_P : Specific heat 0.24 kcal/kg°C

v : Specific volume 0.86 m³/kg

V_F : Fan air volume 25,845 m³/h

b) Heater inlet(mixed) air temp.

$T_M = T_O \times \beta/100 + T_B \times (100 - \beta)/100$ T_M = 15.5 °C

T_O : Outside air temp. -25 °C

β : Fresh air ratio 10 %

T_B : Return air temp. 20.0 °C

$T_B = T_R - 0.0 \text{ °C}$

c) Heating capacity

① For Heating Q_{HST} = 110,893 kcal/h

$Q_{HST} = V_F \times (1/v) \times (i_D - i_M)$

i_D : Enthalpy of Heater outlet 11.79 kcal/kg

i_M : Enthalpy of Heater inlet 8.1 kcal/kg

V_F : Fan air volume 25,845 m³/h

② For Humidifying

$Q_{HLT} =$ kcal/h

$Q_{HLT} = V_F \times (1/v) \times (i_F - i_D)$

i_F : Enthalpy of Blower outlet

kcal/kg

4) Steam Consumption (for Steam Heater)

a) For Heater

$S_H =$ 0.0 kg/h

$S_H = Q_{HST} \div Y_L$

$Q_{HST} =$ 0 kcal/h

$Y_L =$ - kcal/kg

b) For Humidifier

$S_L =$ 0.0 kg/h

$S_L = Q_{HLT} \div Y_L$

$Q_{HLT} =$ 0 kcal/h

$Y_L =$ - kcal/kg

c) Total Steam Consumption

$S_T =$ 0.0 kg/h

5) Electric power consumption (for Electric heater)

a) For Heater

$E_H =$ 128.9 kW/h

$E_H = Q_{HST} \div P_W$

$Q_{HST} =$ 110,893 kcal/h

$P_W =$ 860 kcal/kW

b) For Humidifier

$E_L =$ 0 kW/h

$E_L = Q_{HLT} \div P_W$

$Q_{HLT} =$ 0 kcal/h

$P_W =$ 860 kcal/kW

c) Total

$E_T =$ 128.9 kW/h